

## **Accurate Heating and Air Conditioning**

License # 1008392 10808 Foothill Blvd., 160-420 Rancho Cucamonga, CA 91730 Tel. 1 (888) 702-4822

PLEASE PAY BY AMOUNT INVOICE DATE 09/10/2020 08/11/2020

## **INVOICE NO. 5833**



Job No.: 5916 Order No.: WO 114-A Site:

Site Address: Van Buren Blvd. Riverside CA 92508

## Description

SM is reporting that their HVAC starting making a weird noise last night. Send tech to investigate and repair as needed. Must seek approval to exceed the NTE.

## (08/06/2020) - Work Note

Upon arrival checked in with manager and gained access to the roof. On the roof located RTU that has a loud squeal noise coming from the blower section. Removed blower door and found blower belt squealing very loudly. Removed belt replaced with (1) A32 drive belt (provided by and tested unit. All ops are normal at this time. Temp splits 51/73.

Please submit payment to: Accurate Heating and Air Conditioning 10808 Foothill Blvd., Ste. 160-420, Rancho Cucamonga, CA 91730 Thank you for your business. Labor
Sub-Total ex Tax
Tax
Total inc Tax
Amount Applied
Balance Due

